

水質検査実績一覧表

施設CD		2												
施設名		佐須奈地区水道												
採水地点		佐須奈地内												
採水区分		浄水												
	年月日	平成37年度現在の水道法水質基準値 (平成37年度現在、水質基準がない検査項目については、検査最終年度の基準値)	2024/04/23	2024/05/21	2024/06/18	2024/07/23	2024/08/20	2024/09/10	2024/10/08	2024/11/12	2024/12/17	2025/01/21	2025/02/18	2025/03/11
	検査区分		水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)
	受付番号		57	329	489	311	763	924	497	1275	1446	641	1772	1906
	採水地点		佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内	佐須奈地内
	気温(℃)		15	19	29	30	33	30	20	20	8	5	4	15
項目番号	水温(℃)	18	24	27	28	31	30	25	19	13	10	10	12	
	残留塩素(mg/l)	0.31	0.30	0.30	0.29	0.38	0.38	0.32	0.37	0.33	0.39	0.42	0.32	
1	一般細菌	100 /mL以下	0	0	0	0	0	0	0	0	0	0	0	
2	大腸菌	検出されないこと	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	
3	カドミウム及びその化合物	0.003 mg/L以下	0.0003 未満	-----	-----	0.0003 未満	-----	-----	0.0003 未満	-----	-----	0.0003 未満	-----	
4	水銀及びその化合物	0.0005 mg/L以下	0.00005 未満	-----	-----	0.00005 未満	-----	-----	0.00005 未満	-----	-----	0.00005 未満	-----	
5	セレン及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
6	鉛及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
7	ヒ素及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
8	六価クロム化合物	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
9	亜硝酸態窒素	0.04 mg/L以下	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	
10	シアン化物イオン及び塩化シアン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
11	硝酸態窒素及び亜硝酸態窒素	10 mg/L以下	1.1	-----	-----	1.1	-----	-----	1.6	-----	-----	1.2	-----	
12	フッ素及びその化合物	0.8 mg/L以下	0.08 未満	-----	-----	0.08 未満	-----	-----	0.08 未満	-----	-----	0.08 未満	-----	
13	ホウ素及びその化合物	1.0 mg/L以下	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	
14	四塩化炭素	0.002 mg/L以下	0.0002 未満	-----	-----	0.0002 未満	-----	-----	0.0002 未満	-----	-----	0.0002 未満	-----	
15	1,4-ジオキサン	0.05 mg/L以下	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	
16	シス-1,2-ジクロロエチレン 及びトランス-1,2-ジクロロエチレン	0.04 mg/L以下	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	
17	ジクロロメタン	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
18	テトラクロロエチレン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
19	トリクロロエチレン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
20	ベンゼン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
21	塩素酸	0.6 mg/L以下	0.06 未満	-----	-----	0.14	-----	-----	0.29	-----	-----	0.09	-----	
22	クロロ酢酸	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
23	クロロホルム	0.06 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
24	ジクロロ酢酸	0.03 mg/L以下	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	
25	ジブロモクロロメタン	0.1 mg/L以下	0.002	-----	-----	0.005	-----	-----	0.004	-----	-----	0.001 未満	-----	
26	臭素酸	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
27	総トリハロメタン	0.1 mg/L以下	0.01 未満	-----	-----	0.01 未満	-----	-----	0.01 未満	-----	-----	0.01 未満	-----	
28	トリクロロ酢酸	0.03 mg/L以下	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	
29	ブロモジクロロメタン	0.03 mg/L以下	0.001 未満	-----	-----	0.002	-----	-----	0.001	-----	-----	0.001 未満	-----	
30	ブロモホルム	0.09 mg/L以下	0.009 未満	-----	-----	0.009 未満	-----	-----	0.009 未満	-----	-----	0.009 未満	-----	
31	ホルムアルデヒド	0.08 mg/L以下	0.008 未満	-----	-----	0.008 未満	-----	-----	0.008 未満	-----	-----	0.008 未満	-----	
32	亜鉛及びその化合物	1.0 mg/L以下	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	
33	アルミニウム及びその化合物	0.2 mg/L以下	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	
34	鉄及びその化合物	0.3 mg/L以下	0.03 未満	-----	-----	0.03 未満	-----	-----	0.03 未満	-----	-----	0.03 未満	-----	
35	銅及びその化合物	1.0 mg/L以下	0.007	-----	-----	0.005	-----	-----	0.006	-----	-----	0.005	-----	
36	ナトリウム及びその化合物	200 mg/L以下	10	-----	-----	10	-----	-----	11	-----	-----	11	-----	
37	マンガン及びその化合物	0.05 mg/L以下	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	
38	塩化物イオン	200 mg/L以下	20.7	19.5	19.5	17.0	19.3	18.2	16.9	17.5	16.7	17.6	17.1	18.5
39	カルシウム、マグネシウム等(硬度)	300 mg/L以下	41	-----	-----	40	-----	-----	42	-----	-----	43	-----	
40	蒸発残留物	500 mg/L以下	92	-----	-----	94	-----	-----	93	-----	-----	84	-----	
41	陰イオン界面活性剤	0.2 mg/L以下	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	
42	15,15,16,16-ジクロロヘプタ-2,3,4,5,6,7,8,9,10,11,12,13,14,15-ジクロロヘプタ-2,3,4,5,6,7,8,9													

施設CD		27												
施設名		南部地区水道												
採水地点		女連(消防格納庫)												
検水区分		浄水												
	年月日	平成37年度現在の水道法水質基準値 (平成37年度現在、水質基準がない検査項目については、検査最終年度の基準値)	2024/04/23	2024/05/21	2024/06/18	2024/07/23	2024/08/20	2024/09/10	2024/10/08	2024/11/12	2024/12/17	2025/01/21	2025/02/18	2025/03/11
	検査区分		水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)	水質検査(基準項目)	水質検査(毎月項目)	水質検査(毎月項目)
	受付番号		60	332	492	314	766	927	500	1278	1449	644	1775	1909
	採水地点		女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)	女連(消防格納庫)
	気温(℃)		15	19	29	30	33	30	20	20	8	5	4	15
項目番号	水温(℃)	17	21	27	24	27	26	22	20	13	12	11	12	
	残留塩素(mg/l)	0.15	0.47	0.22	0.18	0.36	0.24	0.38	0.25	0.32	0.29	0.43	0.16	
1	一般細菌	100 /mL以下	0	0	0	0	0	0	0	0	1	0	0	
2	大腸菌	検出されないこと	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	検出しない	
3	カドミウム及びその化合物	0.003 mg/L以下	0.0003 未満	-----	-----	0.0003 未満	-----	-----	0.0003 未満	-----	-----	0.0003 未満	-----	
4	水銀及びその化合物	0.0005 mg/L以下	0.00005 未満	-----	-----	0.00005 未満	-----	-----	0.00005 未満	-----	-----	0.00005 未満	-----	
5	セレン及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
6	鉛及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
7	ヒ素及びその化合物	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
8	六価クロム化合物	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
9	亜硝酸態窒素	0.04 mg/L以下	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	
10	シアン化物イオン及び塩化シアン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
11	硝酸態窒素及び亜硝酸態窒素	10 mg/L以下	1.5	-----	-----	0.9	-----	-----	1.8	-----	-----	1.3	-----	
12	フッ素及びその化合物	0.8 mg/L以下	0.08 未満	-----	-----	0.08 未満	-----	-----	0.08 未満	-----	-----	0.08 未満	-----	
13	ボウ素及びその化合物	1.0 mg/L以下	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	
14	四塩化炭素	0.002 mg/L以下	0.0002 未満	-----	-----	0.0002 未満	-----	-----	0.0002 未満	-----	-----	0.0002 未満	-----	
15	1,4-ジオキサン	0.05 mg/L以下	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	
16	シス-1,2-ジクロロエチレン 及び 反-1,2-ジクロロエチレン	0.04 mg/L以下	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	-----	0.004 未満	-----	
17	ジクロロメタン	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
18	テトラクロロエチレン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
19	トリクロロエチレン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
20	ベンゼン	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
21	塩素酸	0.6 mg/L以下	0.06 未満	-----	-----	0.06 未満	-----	-----	0.07	-----	-----	0.06 未満	-----	
22	クロロ酢酸	0.02 mg/L以下	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	-----	0.002 未満	-----	
23	クロホルム	0.06 mg/L以下	0.001 未満	-----	-----	0.002	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
24	ジクロロ酢酸	0.03 mg/L以下	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	
25	ジブロモクロロメタン	0.1 mg/L以下	0.003	-----	-----	0.005	-----	-----	0.002	-----	-----	0.002	-----	
26	臭素酸	0.01 mg/L以下	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
27	総トリハロメタン	0.1 mg/L以下	0.01 未満	-----	-----	0.01	-----	-----	0.01 未満	-----	-----	0.01 未満	-----	
28	トリクロロ酢酸	0.03 mg/L以下	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	-----	0.003 未満	-----	
29	ブロモジクロロメタン	0.03 mg/L以下	0.001 未満	-----	-----	0.004	-----	-----	0.001 未満	-----	-----	0.001 未満	-----	
30	ブロモホルム	0.09 mg/L以下	0.009 未満	-----	-----	0.009 未満	-----	-----	0.009 未満	-----	-----	0.009 未満	-----	
31	ホルムアルデヒド	0.08 mg/L以下	0.008 未満	-----	-----	0.008 未満	-----	-----	0.008 未満	-----	-----	0.008 未満	-----	
32	亜鉛及びその化合物	1.0 mg/L以下	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	-----	0.05 未満	-----	
33	アルミニウム及びその化合物	0.2 mg/L以下	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	
34	鉄及びその化合物	0.3 mg/L以下	0.03 未満	-----	-----	0.03 未満	-----	-----	0.03 未満	-----	-----	0.03 未満	-----	
35	銅及びその化合物	1.0 mg/L以下	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	
36	ナトリウム及びその化合物	200 mg/L以下	11	-----	-----	10	-----	-----	11	-----	-----	11	-----	
37	マンガン及びその化合物	0.05 mg/L以下	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	-----	0.005 未満	-----	
38	塩化物イオン	200 mg/L以下	17.6	16.3	16.5	14.8	15.6	13.8	13.5	13.7	13.7	15.1	14.8	15.6
39	カルシウム、マグネシウム等(硬度)	300 mg/L以下	56	-----	-----	40	-----	-----	45	-----	-----	57	-----	
40	蒸発残留物	500 mg/L以下	106	-----	-----	93	-----	-----	96	-----	-----	101	-----	
41	陰イオン界面活性剤	0.2 mg/L以下	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	-----	0.02 未満	-----	
42	15.46.6													